## NOTES: 1. GROOVING DETAIL PER CALTRANS STANDARD PLANS DETAIL. 2. ALL SLOPED SURFACES SHALL BE ROUGH BROOM FINISH FOR MARKED CONTRAST FROM BACK OF WALK SIDEWALK FINISH. SIDEWALK 9'-0" CONSTRUCTION **PARKWAY** JOINT SLOPE SLOPE SLOPE FACE OF CURB **GUTTER** 1'-6" 1'-6" 4'-0" WEAKENED PLANE JOINT OR CUT JOINT 1/8" WIDE, 2" DEEP **ELEVATION** Æ 7'-0" 4'-6" S=12:1 MAX. -S= 1/4" PER FOOT 3 1/2" P.C.C. - 3" CLASS III AGGREGATE BASE - 6" CLASS III AGGREGATE BASE (OR AS SPECIFIED ON PLANS) SECTION A-A APPROYED BY

DATE 4/10/92

QD m

WHEELCHAIR RAMP CENTER OF RETURN, DETACHED SIDEWALK

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

**R-8**